

FIRE SAFETY CERTIFICATE

No: 143/NOC/DFO/BELAGAVI/2023


Date: 13-06-2023

Certified that the **Kranthiveera Sangolli Rayanna Sainik School, Sangolli, Bailhongal Taluk, Belagavi District**. Comprised of **Ground & Two Upper Floor** Owned/Occupied by **Kranthiveera Sangolli Rayanna Sainik School, Sangolli** have complied with the fire prevention and fire safety requirements in accordance with rule of State/UT Fire Service Rules, and verified by the **Fire Station Officer, Bailhongal Fire Service** on **12-06-2023** in the presence of The Principal, **Lt Col. Karmachandran (Retd)** and that the Building/Premises is fit for occupancy upto classes Xth with effect **from 12-06-2023 for a period of One Year** in accordance with rule and subject to compliance of specific conditions as appended:-

1. Maintenance of all fire fighting installations periodically
- 2.
- 3.
- 4.

Issued on ~~13~~ 06-2023 at Belagavi, by

*Strike out whichever is not applicable.


 District Fire Officer
 Karnataka State Fire And Emergency Services
 Belagavi-01
 : S.S.Nilgar
 : District Fire Officer
 of Department/Office : Office of the District Fire Officer
 Karnataka State Fire & Emergency
 Services, Khanapur Road, Near
 Goaves Circle, Belagavi-590001.

To,
The Principal
Kranthiveera Sangolli Rayanna Sainik School,
Sangolli, Bailhongal Taluk, Belagavi District.

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to

.....

(Name and Designation of the authorized signatory)

*The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with original vernacular certificate as a single file.

Office of the District Fire Officer
Karnataka State Fire
and Emergency Services
Khanapur Road, Belagavi-590001



Phone : 0831-2429441
E-Mail : dfobgv@gmail.com

C.NO/143/NOC/DFO/BELAGAVI/2023

Date : 13-06-2023

To,
The Principal
Kranthiveera Sangolli Rayanna Sainik School, Sangolli,
Bailhongal Taluk , Belagavi District- 591115

Sir,

Sub: Issue of 'NOC' to Kranthiveera Sangolli Rayanna Sainik School, Sangolli
Bailhongal Taluk, Belagavi District.

Ref: 1) C.No/11/FSO/Bailhongal/2023 Date- 12/06/2023

*_*_*_*_*_*_*_*_*_*

With reference to the subject above cited, the premises of **Kranthiveera Sangolli Rayanna Sainik School**, building consisting with Ground and 2 Upper floors situated at **Sangolli Village, Bailhongal Taluk, Belagavi District** was inspected by Fire Station Officer Bailhongal, on 12/06/2023 with respect to fire Prevention, Fire Fighting & Evacuation point of view for the purpose of issuing **NOC** and the details as under.

ANNEXURE-1

(Up to 14.99 mtrs. In height)

"GROUP-B Educational Buildings

NBC-2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings Sub division B1 & B2.

(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory.)

A. Details of the Building/Premises.

01	Name and Address of the Applicant	The Principal Kranthiveera Sangolli Rayanna Sainik School , Sangolli, Bailhongal Taluk, Belagavi District- 591115
02	Name and Address of the Premises	Kranthiveera Sangolli Rayanna Sainik School , Sangolli, Bailhongal Taluk , Belagavi District- 591115
03.	Name and Address of the Building Owner	The Principal Kranthiveera Sangolli Rayanna Sainik School , Sangolli, Bailhongal Taluk , Belagavi District- 591115
04.	Number of Building	01
05.	Number of Floors	Ground & 2 Upper floors
06.	Floor-wise details of Occupancy:-	
	Ground Floor	Principal Chamber, Record roomAdmin Office , Staff room,-Class room- 02 no, Science lab-01, Yoga Hall -01.
	1 st Floor	Science lab -01, Library-01, Class room-01

	2 nd Floor	Computer lab-01, Yoga Hall-01, Seminar hall-01 & Class room -04.
07.	Height of the building	12.00 Mtr
08.	Site area	70 Acer
09.	Built-up area of each floor:-	
	Ground Floor	1233.80 Sq mtr
	1 st Floor	1176.65 Sq mtr
	2 nd Floor	1108.01 Sq mtr
10.	Total Built-up area	3509.46 Sq mtr
11.	Surrounding properties:-	
	East	Agricultural land
	West	Service road
	North	Front road
	South	Agricultural land
12.	Open Space all around the building	
	East	Nil
	West	Nil
	North	Open area
	South	Nil
Allowed Setbacks (open space) should be maintained free from further obstruction/construction.		

On the inspection of this School/College premises, the following Fire Prevention, Fire Fighting and Evacuation Measures recommended are considered absolutely essential from fire safety point of view:-

Sl. No (01)	Details (02)	Existing (03)		Recommendations (04)
01.	Accessibility to the premises	The premises is accessible from 06.00 mtr road located on the Northern side .		Adequate
02.	Number of Entrances	01 entry & 01 exit no. of 07 mtr wide on the northern side.		Adequate
03.	Number of Staircase	No of staircase	01	Complied
		Width of the staircase	02.70 mtr	
		Width of threads	0.90 mtr	
		Height of risers	0.30 mtr	
		No of risers per flight	0.15 mtr	
		Height of the hand drill.	13 nos.	



B. S. S.
-73/06/23

04.	Portable Extinguishers	04 nos. of 6 Kg capacity ABC type extinguishers and 04 nos. of 4 Kg capacity water type extinguisher has been provided. All the extinguishers suggested are BIS markings and are located at an easily accessible position without obstructing the normal passage.	Complied
05.	Hose reel hose system	03 nos. of hose reel hose has been provided. The hose reel hose of min 19 mm size and of 30 mtrs length has been provided to reach the farthest point of each floor and shut off branch having a nozzle of 05 mm size.	Complied
06.	At the terrace tank level with minimum pressure of 3.5 kg/cm ²	The system has been connected to booster pump of 450 LPM capacity has been provided. Further the system also has been connected to alternative source of power supply.	Complied
07.	Diesel Generator	01 no.of 500 KVA capacity generator has been provided.	Complied
08.	Terrace Tank	RCC overhead tank of 20000 ltr capacity has been provided.	Adequate
09.	Escape routes	Direction in which the the students/teachers have to move in the event of emergency have been indicated in the corridor/passage as a guide during evacuation .	Complied.
10.	Fire Order (Fire safety plans)	A notice board indicating the action to be taken by the employees in case of any emergency have been displayed along with the telephone numbers of Bailhongal Fire station i.e 08288-233100, 101 & 080-22971550, 22971500, 22971600 the telephone nos nearest ambulance services and police station.	Complied
11.	No Smoking board	COPTA Sec-4 direction of No Smoking area, smoking here is an offence board is written in the English & Kannada both languages and is displayed inside the entry/exit of the each floor.	Complied
12.	Fire Siren	A fire siren has been installed in the premises to inform the students/teachers in case of a fire emergency and evacuate the area.	Complied



13.	Nominate One Fire Nodal Officer	Shri Vijay Kulkarni has been nominated as fire nodal officers.	Complied
14.	Fire Fighting Training	Not Imparted	At least 40% of the Teaching and non Teaching staff should be got trained in basic fire fighting at R.A.Mundkur Fire & Emergency Services Academy, Bannerughatta Road, Bangalore or Regional training centre.
15.	<p><u>Fire Precautionary Measures</u></p> <p>A :- Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises.</p> <p>B:- Accumulation of combustibile waste in and around the premises should be avoided.</p> <p>C:- The Exit ways shall be always kept clear without any obstruction.</p> <p>D:- Liquefied petroleum gas should not be stored in the building.</p> <p>E:- The doors shall not be kept locked/ latched during working hours and shall be free from obstruction.</p> <p>F:- During the class hours the class room door shall not be locked from inside to out side.</p> <p>G:- As per Honorable Supreme Court order all teachers and staff shall be trained to handle safety equipments, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14th of every year by conducting Fire Safety drills with co-ordination with the fire services department.</p>		

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing "NOC" to **Kranthiveera Sangolli Rayanna Sainik School, Sangolli Village, Bailhongal Taluk, Belagavi District**. As they have complied all the recommendations as per reference 1. The staff should get trained in the basic fire fighting at Training Centre R.A.Mundkur Fire & Emergency Services Academy, Bannerughatta Road, Bangalore or Regional training centre Hubballi.

This "NOC" is valid for only one year from the date of issue and is renewable.



Yours Faithfully

District Fire Officer
Karnataka State Fire And Emergency Services
Belagevi-01.

Copy to,
Fire Station Officer, Bailhongal.